



Product Service

# CERTIFICATE

No. Z1 17 01 98200 003

**Holder of Certificate:** Caledonian Cables Limited

1/F., CMA Building, 64-66 Connaught Road Central,  
Central and Western District  
HONG KONG

**Production Facility(ies):**

96882

**Certification Mark:**



**Product:**

**XLPE insulated PVC sheathed cables  
BS 5467 600/1000V armoured cables**

**Model(s):**

**FGD300 1RVMAV-R, FGD400 1RVMV-R**

**Parameters:**

Type:	FGD300 1RVMAV-R: CU/XLPE/AWA/PVC FGD400 1RVMV-R: CU/XLPE/GSWA/PVC
Voltage:	600/1000V
Conductors:	Plain annealed copper wires
Insulation:	XLPE, GP8
Bedding:	Extruded layer of polymeric material
Armour:	FGD300 1RVMAV-R: armoured with aluminium wire FGD400 1RVMV-R: armoured with galvanized steel wire
Sheath:	PVC, Type 9
Sizes:	FGD300 1RVMAV-R: 1C x 1.5mm <sup>2</sup> to 1C x 1000mm <sup>2</sup> FGD400 1RVMV-R: 2C x 1.5mm <sup>2</sup> to 4C x 400mm <sup>2</sup> 5C x 1.5mm <sup>2</sup> to 5C x 70mm <sup>2</sup>

**Tested according to:** BS 5467:1997/A3:2008

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 704101685903-00

**Valid until:** 2022-02-08

**Date,** 2017-02-09

Page 1 of 1

(Yi Zhu)

