



Product Service

CERTIFICATE

No. Z1 17 09 98200 010

Holder of Certificate: Caledonian Cables Limited1/F., CMA Building, 64-66 Connaught Road Central,
Central and Western District
HONG KONG**Production**

96882

Facility(ies):**Certification Mark:****Product:****Flame retardant cables
XLPE insulated, LSZH Sheathed, Power
Cables****Model(s):****FTX300 1RZ1-R (N2XH)
FTX400 1RZ1-R (N2XH)****Parameters:**Voltage: 600/1000V
Conductors: Plain annealed copper wires
Insulation: XLPE, Type GP8
Sheath: LSZH, Type LTS4
Sizes:
FTX300 1RZ1-R (N2XH): 1x1.5mm² to 1x1000mm²
FTX400 1RZ1-R (N2XH): 2x1.5mm² to 5x120mm²**Tested according to:** BS 8573:2012

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 704101716505-00**Valid until:** 2022-09-11**Date,** 2017-09-12

(Yi Zhu)

Page 1 of 1

