



Ref. Certif. No.

HU-002917

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Non-sheathed cables for fixed wiring
Name and address of the applicant	Caledonian Cables Limited 1/F., CMA Building, 64-66 Connaught Road Central, Hong Kong
Name and address of the manufacturer	Caledonian (Shandong) Cables Limited Northeast Plant, Inside of Dianliu Industrial Park, Shizi Park, DongJia Town, Licheng, 250100 Jinan, P. R. CHINA
Name and address of the factory	See on page 2
<i>Note: When more than one factory, please report on page 2</i>	
Ratings and principal characteristics	450/750V
Trademark / Brand (if any)	Caledonian Cables Limited
Customer's Testing Facility (CTF) Stage used	---
Model / Type Ref.	60227 IEC 01 1X1,5...10mm ² 450/750V, 60227 IEC 01 1X1,5...400mm ² 450/750V
Additional information (if necessary may also be reported on page 2)	---
A sample of the product was tested and found to be in conformity with	IEC 60227-3:1993 + AMD1:1997 IEC 60227-1:2007 IEC 60227-2:1997 + AMD1:2003
As shown in the Test Report Ref. No. which forms part of this Certificate	GL1903938

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.com

Date: 2020-05-27

Signature:

Gabor Kassai

IEC

IECEE
CB
SCHEME

Ref. Certif. No.

HU-002917

Factories:

- 1) Caledonian (Shandong) Cables Limited
Northeast Plant, Inside of Dianliu Industrial Park, Shizi Park,
DongJia Town, Licheng, 250100 Jinan, P. R. CHINA

- 2) Caledonian (Shandong) Cables Limited Jiyang Branch
No. 17 Yellow River Street, Jibei Develop Zone, Jiyang District,
251400, Jinan Provice, P. R. CHINA

Additional information (if necessary)



TÜVRheinland®

TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.com

Date: 2020-05-27

Signature:

Gabor Kassai