



Product Service

CERTIFICATE

No. Z1 17 08 98200 009

Holder of Certificate: **Caledonian Cables Limited**
 1/F., CMA Building, 64-66 Connaught Road Central,
 Central and Western District
 HONG KONG

Production Facility(ies): 96882

Certification Mark:



Product: **Flame retardant cables
 XLPE insulated, LSZH Sheathed, Power
 Cables**

Model(s): **FTX300 07RZ1-U/R (6181B)
 FTX200 07RZ1-U/R (6182B-6185B)**

Parameters:

Voltage:	450/750V
Conductors:	Plain annealed copper wires
Insulation:	XLPE, Type GP8
Sheath:	LSZH, Type LTS4
Sizes:	
	FTX300 07RZ1-U/R (6181B): 1x1.0mm ² to 1x35mm ²
	FTX200 07RZ1-U/R (6182B-6185B): 2x1.0mm ² to 5x35mm ²

Tested according to: BS 7211:2012

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 704101716504-00

Valid until: 2022-09-06

Date, 2017-09-07

(Yi Zhu)

Page 1 of 1

