



Product Service

CERTIFICATE

No. B 18 04 98200 020

Holder of Certificate: **Caledonian Cables Limited**
1/F., CMA Building, 64-66 Connaught Road Central,
Central and Western District
HONG KONG

Production Facility(ies): 96882

Certification Mark:

Product: **PVC insulated, PVC sheathed flexible cords
Flexible cables with thermoplastic PVC
insulation**

Model(s): **FGD200 05V2V2-F/ HT105 05V2V2-F
HAR Code: H05V2V2-F**

Parameters:

Voltage:	300/500V
Conductors:	Class 5
Insulation:	Thermoplastic compound of Type TI 3
Sheath:	Thermoplastic compound of Type TM 3
Size:	2, 3, 4 and 5 x 0,75 mm ² to 4mm ²

Tested according to: EN 50525-2-11:2011

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 704101835202-00

Valid until: 2023-04-10

Date, 2018-04-11

(Yi Zhu)

Page 1 of 1

