



Product Service

# Attestation of Conformity

No. N8A 18 02 98200 017

**Holder of Certificate: Caledonian Cables Limited**1/F., CMA Building, 64-66 Connaught Road Central,  
Central and Western District  
HONG KONG**Product:****PVC insulated, PVC sheathed flexible cords  
Flexible cables with thermoplastic PVC  
insulation****Model(s):****FGD200 05VV-F (CU/PVC/PVC 300/500V Class 5)  
BS Code:3182Y/3183Y/3184Y/3185Y  
HAR Code:H05VV-F****Parameters:**Voltage: 300/500V  
Conductors: Class 5  
Insulation: Thermoplastic compound of Type Tl 2  
Sheath: Thermoplastic compound of Type TM 2  
Size: 2, 3, 4 and 5 x 0,75 mm<sup>2</sup> to 4mm<sup>2</sup>**Tested  
according to:**


EN 50525-2-11:2011

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

**Test report no.:**

704101716508-00

Date, 2018-02-13

  
(Yi Zhu)

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

Page 1 of 1