



Product Service

CERTIFICATE

No. B 098200 0040 Rev. 00

Holder of Certificate: Caledonian Cables Limited

1/F., CMA Building, 64-66 Connaught Road Central,
Central and Western District
HONG KONG

Production 096882

Facility(ies):

Certification Mark:



**Product: Fire Resistant Cables
(Single Core Non-sheathed Power Cables)**

Model(s): FFX100 07mZ-R

Parameters:

Rated voltage:	450/750V
Conductors:	Plain or tinned copper wire
Fire barrier:	Mica glass tape
Insulation:	Crosslinked LSZH compound, EI 5
Sizes:	1 x 1.5mm ² to 1 x 70mm ²
Fire resistance category:	BS 8592, BS 6387 CWZ

Tested according to: BS 8592:2016

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 64105203045101
Valid until: 2026-01-12

Date, 2021-01-13

(Silvia Zou)