



Product Service

CERTIFICATE

No. B 098200 0032 Rev. 00

Holder of Certificate: **Caledonian Cables Limited**
1/F., CMA Building, 64-66 Connaught Road Central,
Central and Western District
HONG KONG

Certification Mark:



Product: **Flame retardant cables**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 64100180446201

Valid until: 2023-10-10

Date, 2018-10-11 (Boris Ouyang)





Product Service

CERTIFICATE

No. B 098200 0032 Rev. 00

Model(s): FGD400 1VCV-R (NYCY),
FGD400 1VCVMV-R (NYCYRY)

Parameters:

Rated voltage	600/1000V
Conductors:	Annealed copper wire
Insulation:	PVC/A
Concentric conductor:	Copper wire and copper tape
Inner Covering: (For armoured type)	FGD400 1VCVMV-R (NYCYRY): Extruded PVC or polymeric compound
Armour: (For armoured type)	FGD400 1VCVMV-R (NYCYRY): Armoured with galvanized steel wire
Sheath:	Extruded PVC Type ST ₁ /ST ₂
Size	2C x 1.5mm ² to 5C x 630mm ² , 7C x 1.5mm ² to 48C x 2.5mm ²

Tested according to: IEC 60502-1:2004/A1:2009

Production 096882

Facility(ies):

TUV SUD
ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT

A4 / 07.17