

TÜV SÜD
ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



Product Service

CERTIFICATE

No. B 098200 0033 Rev. 00

Holder of Certificate: **Caledonian Cables Limited**
1/F., CMA Building, 64-66 Connaught Road Central,
Central and Western District
HONG KONG

Certification Mark:




Product: **Flame retardant cables**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 64100180446301

Valid until: 2023-10-10

Date, 2018-10-11


(Boris Ouyang)



Product Service

CERTIFICATE

No. B 098200 0033 Rev. 00

Model(s): FTX300 1RZ1-R (N2XH),
FTX400 1RZ1-R (N2XH),
FTX300 1RZ1MAZ1-R (N2XRH),
FTX400 1RZ1MZ1-R (N2XRH)

Parameters:

Rated voltage	600/1000V
Conductors:	Annealed copper wire
Insulation:	XLPE
Inner Covering: (For armoured types):	FTX300 1RZ1MAZ1-R (N2XRH), FTX400 1RZ1MZ1-R (N2XRH): Thermoplastic halogen free compound
Armour: (For armoured types):	FTX300 1RZ1MAZ1-R (N2XRH): Armoured with aluminium wire FTX400 1RZ1MZ1-R (N2XRH): Armoured with galvanized steel wire
Sheath:	Thermoplastic halogen free compound ST ₈
Size:	1C x 1.5mm ² to 800mm ² , 2C x 1.5mm ² to 5C x 400mm ² , 7C x 1.5mm ² to 48C x 2.5mm ²

Tested according to: IEC 60502-1:2004/A1:2009

Production 096882

Facility(ies):

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT